

RFQ# 353-21-117 Questions and Answers

1. Since the questions will be answered and posted by December 14, 2021 @ 5:00 PM and a Bid Bond is required, would the County be open to extending the proposal due date to Monday, December 20, 2021 @ 11:00 AM in order to allow for any changes to the proposal response related to the answers to the questions?
Anyone that was at the walk-thru will have an extension provided to them via email.

2. Is the project registered with a Prevailing Wage determination?
All work in Scranton, PA must have Prevailing Wage.

3. Are Performance, Payment or Maintenance bonds required?
As of this posting yes, for all three but this may change with the extension posting.

4. What is the construction due date of the project?
This will be discussed with the winning organization.

5. Are there any designated work hours for the building sites?
All hours of operation inside the Courthouse, Family Courtrooms, and the Criminal Justice Center are controlled by the Court Administrators anything outside of that is normal business hours.
 - a. If these vary by building, please advise.
Please see above.

6. Will building floor plans be provided prior to the bid due date?
The available floor plans will be presented prior to bid due date.

7. Will the floor plans illustrate the termination locations and internal pathways?
We will verify and not if they do or not when they are emailed out.

8. The RFP states that 24 Strand Single Mode Fiber is required. Does the interior fiber need to be armored? Is plenum or riser rated cable required for the interior fiber runs?
Armored plenum is what we are asking for.